

HYDRAULIC PLACARD

10/05/2008

This system as shown on

Dwg. No 1 of 1 Dated 8/29/2008

for BUILDING

contract no T-08-08-01

at Unknown Unknown

is designed to discharge at a rate of 0.1 GPM/Sq.FT

of floor area over a maximum area of 1500 Sq.FT

when supplied with water at a rate of 759.7 flow (GPM) at 153.022 pressure (PSI)

at the connection to the water supply (hydraulic node 1).

Inside hose stream allowance of 50 (GPM) is included in the above.

Occupancy classification is Office

Commodity classification is

Maximum storage height is 0 (FT)

Comments:

See hydraulics for complete details.

DO NOT REMOVE THIS PLACARD